

PRODUCT CERTIFICATE

Finished Product Laboratory

ISO 13006-10545

Equivalent to the Brazilian Norm NBR 15463/NBR 13818

Dry-pressed ceramic tiles with low water absorption $E_b \leq 0,5\%$

PRODUCT: STILL NOW SAND 120X270

Natural Rectified

TIPOLOGY: PORCELAIN TILE

SIZE: 120X270

CODE: 29934E

LINE: STILL NOW



Characteristics	Test as per	Results
Physical		
Water Absorption (%E)	ISO 10545-3 NBR 13818 - annex: B ($E \leq 0,5\%$)	0,5
Modulus of Breaking Strength (MPa)	ISO 10545-4 NBR 13818 - annex: C (NBR 15463 Average: ≥ 37)	37
Breaking Load (N)	ISO 10545-4 NBR 13818 - annex: C (NBR 15463 Average: ≥ 900)	900
Moisture Expansion (mm/m)	ISO 10545-10 NBR 13818 - annex: J	0,1
Crazing Resistance	ISO 10545-11 NBR 13818 - annex: F	Resist
Frost Resistance	ISO 10545-12 NBR 13818 - annex: M	Resist
Resistance to Thermal Shock	ISO 10545-9 NBR 13818 - annex: L	Resist
Chemical		
Resistance to Stains		
Green staining agent in light oil		3
Red staining agent in light oil		3
Iodine	ISO 10545-14 NBR 13818 - annex: G (Minimum: 3)	3
Olive Oil		3
Chemical Resistance		
Hydrochloric Acid 3% (v/v)		B
Potassium Hydroxide 30g/L		B
Citric Acid 100g/L		B
Lactic Acid 5% (v/v)		B
Hydrochloric Acid 18% (v/v)	ISO 10545-13 NBR 13818 - annex: H (Minimum: B)	B
Potassium Hydroxide 100g/L		B
Ammonium Chloride 100g/L		A
Sodium Hypochloride 20mg/L		A

Coefficient of Friction

Dry Surface	NBR 13818 - annex: N Method: TORTUS III (Value \geq 0,4)	0,3
Wet Surface		0,3

Local of Use

Cl - Commercial Light | RE - Residential | FA - Facade

Recommendation for Application

For information on application recommendations, refer to the virtual specifier: <http://especificadorvirtual.portobello.com.br>
Tijucas, 27/01/2021

Portobello



31888c1b3d72a61139b668b52b319eb79e8f

Portobello SA - Factory | contato@portobello.com.br | SAC: 800 648 2002 | BR 101 - Km 163 - PO Box 15 - Tijucas/SC - Brazil - 88200-000